

**Office of Sub Divisional Engineer**  
**Water Supply and Sanitation Sub Division**  
**No.2, Jalandhar**

**Certificate**

No. 452


Date 16.08-2022


**To Whom it May concern**


Certify that an inspection has been done of CT WORLD SCHOOL Shahpur,  
Distt. Jalandhar and found as under :-

1. That the drinking water facilities for the students and the members of staff are maintained properly in the School building at present .
2. That the institution is maintaining the hygienic sanitation condition in the school building at present.

The above certificate valid for one year from the date of issue .

  
Sub-Divisional Engineer  
Water Supply & Sanitation  
Sub Division No.2, Jalandhar

  
Principal  
C T World School  
Jalandhar

For CT Educational Society  
  
Joint Secretary



Office Of Sub Divisional Engineer,  
Water Supply & Sanitation, Sub Division No.2,  
Jalandhar



## Certificate


No: 322.....


Date 09/06/22


### TO WHOM IT MAY CONCERN

Certify that an inspection has been done of CT World School, Shahpur Distt Jalandhar and found that the institution is maintaining the hygienic sanitation conditions in the school building at present.

The above certificate is valid upto one year from the date of issue.

  
Sub Divisional Engineer  
Water supply and sanitation  
Sub divisional no. 2 jalandhar

  
Principal  
C T World School  
Jalandhar

For CT Educational Society  
  
Joint Secretary

# District Water Testing Laboratory, Jalandhar.

(Deptt. of Water Supply and Sanitation, Jalandhar.)

E-mail: [dwtljalandhar@gmail.com](mailto:dwtljalandhar@gmail.com)

Ref. No. DwtlJAL/064

Dated: 31/5/2022

To

CT World School

6687 Road Jalandhar


**Subject: Test reports of water samples.**


Please find the enclosed herewith the report no. DwtlJAL/064


dated 31/5/2022. You are requested to fill the attached feedback form and send it District Water Testing Laboratory, Jalandhar.

Samples received on 12/5/2022.

**D/A: Test Report**

  
Quality Manager/ Sr. Chemist  
District Water Testing Laboratory,  
Jalandhar

  
Principal  
C T World School  
Jalandhar

For CT Educational Society  
  
Joint Secretary

ID No. DWL 701/064

Dated 31/8/2022

Sample Registration No. :

Sample code given by customer : Not Applicable

Test Results

Chemical Testing

Basic Chemical Parameters (As per IS 10500 : 2012)						
Sr. No.	Parameter	Acceptable limit mg/l	Permissible Limit mg/l	Method Detection Limit (MDL) (mg/l)	Result	Standard / Specification/ Method Followed
1	pH	6.5-8.5	No relaxation	2.0	As per Annexure Attached	IS3025 Part 11
2	TDS	500	2000	10		IS3025 Part16
3	Turbidity	1.0	5.0	0.5		IS3025 Part10
4	Colour	5.0	15.0	1.0		IS3025 Part4
5	Odour	Agreeable	Agreeable	-		IS3025 Part5
6	Taste	Agreeable	Agreeable	-		IS3025 Part8
7	Total Hardness	200	600	2.0		IS3025 Part21
8	Total Alkalinity	200	600	2.0		IS3025 Part23
9	Calcium	75	200	2.0		IS3025 Part40
10	Magnesium	30	100	2.0		APHA 23 <sup>rd</sup> Edition 3500-MgB
11	Chloride	250	1000	2.0		IS3025 Part32
				mg/l: milligram per liter TDS: Total Dissolved Solids	MDL - Method Detection Limit	
<b>Note 1:</b>	APHA: American Public Health Association IS: Indian Standard Method			BDL- Below Detection Limit		

*[Signature]*  
Authorized Signatory

*[Signature]*  
Principal  
CT World School  
Jalandhar

For CT Educational Society  
*[Signature]*  
Joint Secretary

(4)

**District Water Testing Laboratory,  
Water Supply and sanitation Deptt., Jalandhar.**

ID No. DWTLJAL/064

Dated 31/5/2022

**TEST REPORT**  
Chemical Testing


Sample Registration No. : DWTLJAL/064

Sample code given by customer : Not Applicable

Issued to: - CT World School 6671 Road Jalandhar


**SAMPLE PARTICULARS**


Ref. Letter No.	: -
Date of Receipt	: 18/5/2022
Sample code given by customer	: N/A
Name / Nature of sample	: water
Condition of the sample	: unsealed
Qty/Pkg	: 750
Sampling Method	: Sample not drawn by DWTLJAL
Test Start Date	: 18/5/2022
Test Completion Date	: 31/5/2022

  
Quality Manager/ Sr. Chemist  
District Water Testing Laboratory,  
Jalandhar.

**Note:**

- ☞ The enclosed results pertain only to the sample tested.
- ☞ The report shall not be used for advertising or any legal purpose without written permission from the Head, DWSS.
- ☞ This report cannot be re-produced, except when in full, without the written permission from the Head, DWSS.
- ☞ The sample shall be destroyed after one month from the date of issue of the report.

  
Principal  
C T World School  
Jalandhar

For CT Educational Society  
  
Joint Secretary

ID: DWTLJAL/064

Date: 31.05.2022

Sr. No.	Registration No.	District	Block	Name of Place	Sample Receipt Date	Source	Depth	Colour	Taste	Odour	PH	TDS	Turbidity	Total Alkalinity	Total Hardness	Calcium	Magnesium	Chloride	
As per IS 3025:2017 : (Requirement Acceptable Limit-Permissible Limit)						Acceptable Limit			Non-Objectionable	Non-Objectionable	6.5-8.5	500 mg/l	1 NTU	200 mg/l	200 mg/l	75 mg/l	30 mg/l	250 mg/l	
						Permissible Limit			Non-Objectionable	Non-Objectionable	No Relaxation	2000 mg/l	5 NTU	600 mg/l	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	
<b>Test Result</b>																			
1	DWTLJAL/0522/C/064	Jalandhar	Jal west	66FT Road	31.05.2022	T/WELL		4	Agreeable	Agreeable	7.84	290	0.40	260	272	43.98	38.9	32.0	
2	DWTLJAL/0522/C/064	Jalandhar	Jal west	66FT Road	31.05.2022	RO		2	Agreeable	Agreeable	7.25	180	0.3	156	164	33.66	19.44	18.2	

*S. L. Singh*  
Principal  
C T World School  
Jalandhar

*[Signature]*  
Quality Manager  
District Water Testing Laboratory,  
Jalandhar.

For CT Educational Society  
*[Signature]*  
Joint Secretary